



CRITTENDEN FIRE RESCUE

104 North Main Street Mail to: P.O. Box 100

Crittenden, Ky. 41030-0100

Phone (859) 428 - 1767 Fax (859) 428 - 1419



FIRE LIFE SAFETY INSPECTION CHECKLIST (2018 IFC/ KY KFS Code 1)

Building Location/Address:		Inspection Date:
Business Name:		Business Type:
Phone No.:		Structure Type: Class <input type="radio"/> I <input type="radio"/> II <input type="radio"/> III <input type="radio"/> IV <input type="radio"/> V
Owners Name:		Reinspect (30 days): <input type="radio"/> Yes - Visit #: ____ <input type="radio"/> Final
Phone No.:		Final Issued date:
email:		
Contact person:	Inspected by and ID.#:	

INSPECTION ITEMS		P	F	NA	COMMENTS
A. EXITS					
1	Max Occupancy posted at main entrance proximity				
2	Egress doors readily openable from egress side.				
3	Exit signs illuminated w/proper backup.				
4	Exit signs provided at required intervals.				
5	Emergency lighting systems functional.				
6	No obstructions along path of egress.				
7	Electrically operated doors egress w/o power .				
8	Handrails and guardrails provided & maintained.				
B. FIRE SAFETY & EVACUATON PLANS					
1	Premises clearly identified with Arabic numerals 3" minimum posted in a street side "A" location.				
2	Floor plan schematic posted with exits marked				
3	Fire safety & evacuation plan readily available				
4	Fire safety & evacuation plan posted accordingly				
5	Evacuation drill conducted annually.				
6	Elevator(s) operational & valid inspection certificate from KY Department of L&I on site.				
C. HOUSEKEEPING					
1	All areas free from combustible waste accumulation.				
2	Combustible materials kept free of ignition sources				
3	Boiler, mechanical, electrical, heat, inspection permits visible.				
4	Dumpsters >40 cf shall be 10ft. from bldg.				
5	All oily & greasy rags kept in self closing metal cans				
6	No holes present in walls, ceilings, floors				
7	All utility controls covered with access for emergency				
8	Passage of cables, electrical lines, piping, ductwork sealed, no openings through walls, ceiling, floors				
9	No storage under stairs to exceed 35% of open space				
10	No Flammable liquids, operating electrical or heat source stored under stairs				



CRITTENDEN FIRE RESCUE

104 North Main Street Mail to: P.O. Box 100

Crittenden, Ky. 41030-0100

Phone (859) 428 - 1767 Fax (859) 428 - 1419



D. FIRE PREVENTION/FIRE PROTECTION		P	F	NA
1	Smoke detectors present in each bedroom, common room (kitchen exempt) and stairway landings. Not exposed to points of steam or natural exhaust. Monthly test record/log kept.			
2	Carbon Monoxide detectors present. Operational. Tested monthly. Records/log.			
3	Carbon Monoxide detectors placed properly			
4	Fire alarm systems inspected, tested & maintained in accordance with NFPA-72. Test records available.			
5	Sprinkler systems (water) inspected, tested & maintained with NFPA-25. Test records available.			
6	Standpipe systems shall be inspected & maintained annually in accordance with NFPA-25. Records.			
7	Sprinkler system is pressurized & functional all zones.			
8	Sprinkler heads unobstructed, 18 in. free clearance			
9	Unobstructed access to all fire protection equipment:			

E. FDC-Sprinklers, Extinguishers, Etc.		P	F	NA
1	Private fire hydrants inspected annually.			
2	Fire lanes unobstructed and accessible.			
3	Fire extinguishers available, visible, unobstructed			
4	Fire extinguishers inspected annually. (NFPA-10)			
5	Type K extinguisher installed & maintained w/in 30 ft of commercial cooking equipment.			
6	Cooking hoods, grease free, removal devices, fans, ducts, are clean and operational			
7	Self-closing fire doors function & free of obstruction			
8	Emergency power systems shall be maintained and tested in accordance with NFPA 110, 111.			

F. ELECTRICAL		P	F	NA
1	Electrical wiring, devices, equipment in good condition			
2	Conduit present when wiring exposed ending at electrical box			
3	Working clearance and access shall be provided around all electrical service equipment.			
4	Extension cords not used as permanent wiring.			
5	Electrical controls/Panel Boxes accessible with 18" perimeter free of debris, storage, or hinderance			
6	Electrical GFI or ARC Sensor-Breaker present on all laundry and bath/toilet room circuits			
7	GFI or ARC Breakers present on electrical outlets within 48" of water faucets, sources or drains			
8	All outlet boxes for cable, electrical, switching, phone with covers not broken and secured			

